

PLAN AT EL. 52.40

SCALE 1:100



PLAN AT EL. 46.65

SCALE 1:100



SECTION 1-1

SCALE 1:100

MIN. WL	MINIMUM WATER LEVEL
MAX. WL	MAXIMUM WATER LEVEL

LEGENDS

	KNIFE EDGE GATE VALVE
	NRV
	DISMANTLING JOINT

NOTES

1. ALL DIMENSIONS ARE IN MILLIMETERS AND ELEVATIONS ARE IN METERS UNLESS OTHERWISE SPECIFIED.
2. ALL PIPES, FLANGES AND FITTINGS SHALL BE OF DUCTILE IRON.
3. PIPES SHALL BE AS PER IS:8329 STANDARD OF CLASS K9 AND PIPE FLANGE OF RATING PN10.
4. ALL FITTINGS SHALL BE AS PER IS:9523 STANDARD OF CLASS K12 AND FLA OF RATING PN10.

FIGURE 1: GA OF TERMINAL SEWAGE PUMPING STATION

TENDER PURPOSE ONLY

ALL THE LEVELS AND DIMENSIONS ARE INDICATIVE.
DETAIL & DESIGN DRAWINGS SHOULD BE PREPARED
BY THE CONTRACTOR AFTER PERFORMING NECESSARY INVESTIGATION.

GUWAHATI SMART CITY LIMITED

DO NOT SCALE

GA DRAWING OF TERMINAL SPS

ISSUE	REVISIONS	DRN	CIVIL	ELEC	I&C	MECH			APPD	DATE
			CLEARED							

TATA CONSULTING ENGINEERS LIMITED
MUMBAI

FOR R0 ISSUE ONLY		
	CLEARED	
DEPT	SIGNATURE	DATE
CIVIL		
ELEC		
I&C		
MECH		

FILE NAME: F-041-Rev-R5.dwg

FILE NAME :

CLIENT : GUWAHATI SMART CITY LIMITED

PROJECT : BORSOLA BEEL DEVELOPMENT PROJECT

SCALE: 1:100	APPROVED	DATE (R0 ISSUE)
DEL.CENTRE-DISC:		DATE (CURRENT ISSUE)
DRN:		
CHD:	DWG NO TCE.10477A-CV-3000-GA-30206	ISSUE

SIZE-A2

TCE FORM NO. 042 R5